

Elementary School "Milinko Kušić" Ivanjica



Gross Area **4740 m²**
 Year of construction **1950/1964**
 Fuel type **Wood**

Investment EUR **≅ 215.000**



Energy efficiency measures

1. Outside Windows and Doors Replacement
2. Old Radiator Valves Replacement with Thermostatic ones and Water softener installation



SAVINGS ESTIMATED					SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	Energy Costs	
MWh	MWh	kg	kg x 10 ³	US\$ x 10 ³	Years
228	478	193	124	6.70	21.20

