

Secondary Agricultural Chemical School "Dr Đorđe Radić" Kraljevo



Gross Area **3996 m²**
 Year of construction **Constructed in 19th century and under the protection**
 Fuel type **Boiler on Coal, situated in other school, 300 m walking distance away**
 Investment EUR



Energy efficiency measures

1. Outside Windows and Doors Replacement
2. Old Radiator Valves Replacement with Thermostatic ones and Variable Flow Pumps Installation



SAVINGS ESTIMATED				SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	
MWh	MWh	kg	kg x 10 ³	Years
142	222	146.064	117	12.89

