

Elementary School Leskovac



Gross Area **2350 m²**
 Year of construction **1904/1937/1978**
 Fuel type **District Heating / Heavy Fuel Oil**

Investment EUR **≅ 45.000**



Energy efficiency measures

1. Roof Thermal Insulation
2. Outer Windows and Doors Replacement
3. Three Way Valve Installation with Control
4. Thermostatic Radiator Valves and Variable Flow Pumps Installation



SAVINGS ESTIMATED				SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	
MWh	MWh	kg	kg x 10 ³	Years
95	137	12.488	37	5.16

