

# Elementary School "12. septembar" Majdanpek



Gross Area **3256 m<sup>2</sup>**  
 Year of construction **1972**  
 Fuel type **District Heating**

Investment EUR **≈ 235.000**



## Energy efficiency measures

1. Outside Windows and Doors Replacement
2. Old Radiator Valves Replacement with Thermostatic ones and Variable Flow Pumps Installation



SAVINGS ESTIMATED					SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO <sub>2</sub> emiss.	Energy Costs	
MWh	MWh	kg	kg x 10 <sup>3</sup>	US\$ x 10 <sup>3</sup>	Years
166	234	29.093	86	14.95	12.50

