

General Hospital Priboj



Gross Area **4510 m²**
 Year of construction **1959/1972**
 Fuel type **Heavy Fuel Oil**

Investment EUR **≅ 100.000**



Energy efficiency measures

1. Reparation of existing windows
2. Replacement of facade single pane glazing
3. Reconstruction / Replacement 3-Way Valves and water softener installation
4. Old Radiator Valves Replacement with Thermostatic ones, Variable Flow Pumps and water softener Installation*
5. Burners Replacement



SAVINGS ESTIMATED					SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	Energy Costs	
MWh	MWh	kg	kg x 10 ³	US\$ x 10 ³	Years
117	515	46.645	134	15.83	7.42

