

Elementary School "Vuk Karadžić" Priboj



Gross Area **4140 m²**
 Year of construction **1959/1972 both parts reconstructed in 2003**
 Fuel type **District Heating**

Investment EUR **≅ 260.000**



Energy efficiency measures

1. Outside Windows and Doors Replacement
2. Heat Exchangers and Piping Insulation
3. Old Radiator Valves Replacement with Thermostatic ones



SAVINGS ESTIMATED					SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	Energy Costs	
MWh	MWh	kg	kg x 10 ³	US\$ x 10 ³	Years
348	465	55.834	164	20.04	8.45

