

General Hospital Prijepolje



Gross Area **6350 m²**
 Year of construction **1948/1962/1973**
 Fuel type **Light Fuel Oil**

Investment EUR **≅ 200.000**



Energy efficiency measures

1. Thermal Insulation of Outside Walls
2. Outside Windows and Doors Replacement
3. Reparation of existing boiler room and switch to heavy fuel oil
4. Old Radiator Valves Replacement with Thermostatic ones and Variable Flow Pumps Installation



SAVINGS ESTIMATED					SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	Energy Costs	
MWh	MWh	kg	kg x 10 ³	US\$ x 10 ³	Years
455	1.093	93.664	257	185.60	2.38

