

Health Centre Šabac Neurology and Pneumofisiology Ward



Gross Area **2926 m²**
 Year of construction **1969**
 Fuel type **Natural Gas**

Investment EUR



Energy efficiency measures

1. Outside Windows Replacement
2. Outside Glazing and Doors Replacement
3. 3-Way Valve, and Variable Flow Pumps Installation
4. Old Radiator Valves Replacement with Thermostatic ones



SAVINGS ESTIMATED					SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	Energy Costs	
MWh	MWh	kg	kg x 10 ³	US\$ x 10 ³	Years
268	459	50.120	87	13.52	8.27

