

Elementary School Surdulica



Gross Area **4975 m²**
 Year of construction **1979**
 Fuel type **Light Fuel Oil**

Investment EUR **≅ 220.000**



Energy efficiency measures

1. Outer Windows and Doors Replacement
2. Heating Pipework Refurbishment
3. Boilers and Burners Replacement
4. Three Way Valve Installation with Controls
5. Thermostatic Radiator Valves and Variable Flow Pumps Installation



SAVINGS ESTIMATED				SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	
MWh	MWh	kg	kg x 10 ³	Years
152	497	42.581	124	7.65

