

CHC - Surgery Clinics Valjevo



Gross Area **9240 m²**
 Year of construction **1980**
 Fuel type **Coal**

Investment EUR **≅ 310.000**



Energy efficiency measures

1. Old Radiator Valves Replacement with Thermostatic ones and Variable Flow Pumps Installation



SAVINGS ESTIMATED					SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	Energy Costs	
MWh	MWh	kg	kg x 10 ³	US\$ x 10 ³	Years
0	141	52.759	42	2.60	7.85

