



Technical School Vranje

Gross Area **3690 m²**
 Year of construction **1970**
 Fuel type **Light Fuel Oil**

Investment EUR **≅ 85.000**



Energy efficiency measures

1. Roof Thermal Insulation
2. Outer Windows and Doors Replacement
3. Over pressure louvers Installation on the Gym
4. Thermostatic Radiator Valves and Variable Flow Pumps Installation



SAVINGS ESTIMATED				SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	
MWh	MWh	kg	kg x 10 ³	Years
105	138	11.796	34	15.72

