

Secondary Agricultural School "Vršac" Vršac



Gross Area **2542 m²**
 Fuel type **Natural Gas**

Investment EUR **≅ 170.000**



Energy efficiency measures

1. Central Stairs Glazing Replacement
2. Outside Windows Replacement
3. Old Radiator Valves Replacement with Thermostatic ones and Variable Flow Pumps Installation



SAVINGS ESTIMATED					SIMPLE PAY BACK
Heating Energy demands	Heating Energy consumption	Fuel Consum.	CO ₂ emiss.	Energy Costs	
MWh	MWh	kg	kg x 10 ³	US\$ x 10 ³	Years
167	603	180.781	181	4.89	23.17

